

T.S.  
*[Signature]*  
**GOVERNMENT OF MEGHALAYA**  
**POWER DEPARTMENT**  
**ORDERS BY THE GOVERNOR**  
**NOTIFICATION**

Dated Shillong the 22<sup>nd</sup> January, 2021

In partial modification of this Department's notification No.POWER-12/2011/191 dt 31.07.2014 and in exercise of the Power conferred by Regulation 32 of Central Electricity Authority Regulation 2010 framed under Section 9 of Indian Electricity Act 2003 read with clause (X) Sub-Section (2) of Section 176 and Sub-Section (1) of Section 162 of Indian Electricity Act 2003, the Governor of Meghalaya is pleased to specify that Diesel Generating Sets/Captive Generation having the Capacity of 9.5 KVA and above shall require inspection and testing by the Electrical Inspector and approval will be accorded in writing before commissioning.

This order will come into effect immediately.

Sd/-  
(Pravin Bakshi)  
Secretary to the Govt. of Meghalaya,  
Power Department.

Memo No.POWER -12/2011/385-A  
Copy to:-

Dated Shillong, the 22<sup>nd</sup> January, 2021

1. The Senior Electrical Inspector, Meghalaya Shillong, for information and wide publication.
2. The Director (Distribution/Generation), Meghalaya Energy Corporation Limited, Shillong.
3. All Administrative Departments.
4. The Director of Printing and Stationery, Meghalaya, Shillong, for publication in the Meghalaya Gazette.
5. Guard file.

By Order etc.,  
*[Signature]*  
Deputy Secretary to the Govt. of Meghalaya  
Power Department